



# ATTESTATION OF CONFORMITY

**Name and Address of Attestation Holder:**

BLITZ- Ksquare Energy Private Ltd  
B-403/404 Signature -2, Sarkhej Sanand Road,Sarkhej,  
Ahmedabad -382210

**Document Number**

CE-2083-01-300724

**Name and Address of Manufacturer:**

BLITZ- Ksquare Energy Private Ltd  
B-403/404 Signature -2, Sarkhej Sanand Road,Sarkhej.  
Ahmedabad -382210

**Date of Issue:**

30.07.2024

**Expiration Date:**

30.07.2029

**Brand:**

BLITZ™

**Test Report Number:**

ZNCT240724002

**Product Name:**

## Surge Protective Device

### Test Required:

EN 61643-31:2019  
IEC 61643-31 Ed.1.0 b:2018

### Product Model:

BLT-DC; Ucpv: DC110V,DC220V,DC500V,DC600V,DC800V,DC1000V,DC1200V,DC1500V;  
In:10KA,20KA,30KA,40KA,50KA; Poles:1P,2P,3P

The product meets the technical requirement of the above standards as mentioned in the reference test reports and hence fulfils the technical requirements of the following directives

## 2014/35/EU Low Voltage Directive

This document is only valid for the equipment and configuration described, in conjunction with the test data detailed above reference test reports. Document was issued on voluntary basis and does not imply meeting Notified Body conformity assessment procedure for the product.

The CE Mark, under the responsibility of the manufacturer or the importer, after completion of an EC Declaration of Conformity and compliance with all relevant EC Directives.

**SIGNATURE**

